

# Advisory Report

**BER Number: voidvoidvoid    Building Energy Rating: B2**

Ballphehane Community Centre  
Tory Top Park  
Cork City  
T12 WC6V

MPRN: 000000000000

Building Type(s): Non-residential Institutions: Community/Day Centre

<b>ADMINISTRATIVE INFORMATION</b>	
Issue Date:	07 Aug 2021
Valid Until:	06 Aug 2031 (*)
Useful Floor Area (m <sup>2</sup> ):	1651.8
Main Heating Fuel:	Natural Gas
Building Environment:	Heating and Natural Ventilation
Calculation Tool Used:	G-ISBEM v23.0 using calculation engine SBEMIE v5.5.h.2
<b>ENERGY ASSESSOR DETAILS</b>	
Assessor Name:	Stephen McGovern
Assessor Company Number:	105080
Assessor Number:	105562
Assessor Scheme:	SEAI

# Table of Contents

1. Background..... 3

2. Introduction..... 3

3. Recommendations..... 4

4. Next Steps..... 6

5. Glossary..... 7

ONLY FOR ILLUSTRATION

## 1. Background

Statutory Instrument No. 666 of 2006, European Communities (Energy Performance of Buildings), gives effect to certain provisions of Directive 2002/91/EC of the European Parliament and of the Council of 16 December 2002 on the energy performance of buildings.

A Building Energy Rating (BER) and advisory report is to be supplied by the owner to a prospective buyer or tenant when constructed, sold or rented. The objective of the rating is twofold:

To give prospective buyers and tenants information about the energy performance of buildings.

To give builders/developers and vendors/landlords, an incentive to upgrade the energy performance of the building by giving visible credit to superior standards.

The BER must be accompanied by an "Advisory Report" setting out recommendations for cost-effective improvements to the energy performance of the building. However there will be no legal obligation on vendors or prospective purchasers to carry out the recommended improvements. This provision of the EPBD has been transposed into Irish legislation by S.I. No. 666 of 2006.

## 2. Introduction

This Advisory Report was produced in line with the approved methodology and is based on calculation tool G-ISBEM v23.0 using calculation engine SBEMIE v5.5.h.2 .

The BER and Advisory Report for new buildings is based upon the design drawings and building specifications taking account of amendments during the construction phase. The focus of the advisory report for new buildings is to provide occupants with advice on to assist them with maximising the energy efficiency of their new building through best use of features and services installed.

For existing buildings the BER and Advisory Report will also be based on a survey of the building.

### 3. Recommendations

The following sections list recommendations selected by the energy assessor for the improvement of the energy performance of the building. The recommendations are listed under four headings: short payback, medium payback, long payback, and other measures.

#### ***a) Recommendations with a short payback***

This section lists recommendations with a payback of less than 3 years:

<b>Recommendation</b>	<b>Potential impact</b>
Install more efficient water heater.	HIGH
Consider replacing HWS with point of use system.	HIGH
Consider replacing T8 lamps with retrofit T5 conversion kit.	MEDIUM
In some spaces, the solar gain limit specified in the NEAP is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	MEDIUM
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	LOW

#### ***b) Recommendations with a medium payback***

This section lists recommendations with a payback of between 3 and 7 years:

<b>Recommendation</b>	<b>Potential impact</b>
Add time control to heating system.	LOW
Add optimum start/stop to the heating system.	LOW
The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.	LOW
Some walls have uninsulated cavities - introduce cavity wall insulation.	MEDIUM

**c) Recommendations with a long payback**

This section lists recommendations with a payback of more than 7 years:

Recommendation	Potential impact
Add local temperature control to the heating system.	LOW
Add weather compensation controls to heating system.	LOW
Add local time control to heating system.	LOW
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	MEDIUM
Consider replacing heating boiler plant with a condensing type.	MEDIUM

**d) Other recommendations**

This section lists other recommendations selected by the energy assessor, based on an understanding of the building, and / or based on a valid existing energy report.

No recommendations defined by the energy assessor have been identified

## 4. Next steps

### **a) Your Advisory Report**

Statutory Instrument No. 666 of 2006 requires that the Building Energy Rating (BER) Certificate must be accompanied by an "Advisory Report" setting out recommendations for cost-effective improvements to the energy performance of the building.

This advisory report has been lodged on the BER register. Access to the report, to the data used to compile the report, and to previous similar documents relating to the same building can be obtained by request through ([www.sei.ie/ber](http://www.sei.ie/ber)) using the report reference number of this document.

### **b) Implementing recommendations**

The recommendations are provided as an indication of opportunities that appear to exist to improve the building's energy efficiency.

The recommendations are derived from a set of recommendations automatically produced by the calculation tool, reviewed, commented on and amended by the BER assessor as he / she found appropriate in the light of his / her knowledge of the building and its current or intended use. Any recommendations in Section 3d (Other recommendations) have been inserted by the BER assessor.

These recommendations do not include matters relating to operation and maintenance which cannot be identified from the calculation procedure.

### **c) Legal disclaimer**

The advice provided in this Advisory Report is intended to be for information only. Recipients of this Advisory Report are advised to seek further detailed professional advice before reaching any decision on how to improve the energy performance of the building.

## 5. Glossary

### **a) Payback**

The payback periods are based primarily on data provided by the UK Good Practice Guides and Carbon Trust energy survey reports and are average figures calculated using a simple payback method. It is assumed that the source data is correct and accurate using up to date information and that these data are applicable to Ireland.

The figures have been calculated as an average across a range of buildings and may differ from the actual payback period for the building being assessed. Therefore, it is recommended that each suggested measure be further investigated before reaching any decision on how to improve the energy efficiency of the building.

### **b) Primary Energy and Carbon Dioxide Emissions Impact**

The High / Medium / Low potential impact indicators against each recommendation are provided to distinguish, between the suggested recommendations, those that would have the most impact on primary energy and carbon dioxide emissions from the building. For automatically generated recommendations, the potential impact indicators are determined by the software, but may have been adjusted by the Energy Assessor based on his / her knowledge of this building. The potential impact of other recommendations is determined by the assessor.

### **c) Valid Advisory Report**

A valid report is a report that has been:

- Produced within the past 10 years
- Produced by a registered Building Energy Rating Assessor
- Lodged on the register managed by Sustainable Energy Ireland.

A provisional BER certificate and related advisory report, where applicable, shall be valid for a period not exceeding 24 months from the date of its issue.